

Annex A

EQUIPMENT CHECKLIST		
Substation/Line Details:_____	Equipment and Type:_____	
Pole/Line Number:_____	Rating:_____ kVA	_____ kV
Serial Number:_____	Date of erection/removal:_____	
Erected/Removed by:_____	Work Order Number:_____	
Task	Defects Repaired Yes/No	Comments
1. Check for any oil/gas leak		
2. Check if modification is already done the Transformer		
3. Inspect the gauge glass		
4. Check metal work for rust/corrosion		
5. Inspect the earth straps condition and effective connection		
6. Check cable connection box/heaters		
7. Check condition of Name Plates & Cautionary Plates		
8. Surge arrestors		
10. Grass & Bushes Trimmed		
Signed:		Date: