


- NOTES:
1. ALL FABRICATED ITEMS, BOLTS, NUTS AND WASHERS SHALL BE HOT DIPPED GALVANISED TO SABS 763.
 2. FOR TRANSFORMER RATED UP TO 25KVA.
 3. ALUMINIUM OXIDE GREASE SHALL BE USED ON ALL CLAMPS FOR CORROSION PROTECTION.
 4. THE A-FRAME MUST BE PROPERLY EARTHED TO SPECIFIED STANDARD.

Copyright © 2009 EMOEN
 All rights reserved. No part of this publication may be reproduced, stored in a retrieval system or transmitted in any form or by any means electronic, mechanical, magnetic, tape, mechanical, photocopying, recording or otherwise, without the permission in writing from EMOEN.

ITEM	DESCRIPTION	QTY	REMARKS
1	DEAD CLAMP	3	PIP- 2874-28
2	THIMBLE END	3	PIP- A0E-280
3	THIMBLE CLEVIS	3	PIP- M1070
4	LONGROD INSULATOR	3	CULLINAN EP 345, 585mm GREENAGE
5	IRON A-FRAME	3	GALVANISED MILD STEEL
6	BITS & WOOD POLE WASHERS	8	SEE DRAWING SHEET-11
7	SPRING ARRESTOR	3	SEE DRAWING V07 COMPLETE
8	TRANSFORMER MOUNTING BRACKET	1	RAB CHANGE DESIGN 0924 10RS
9	TRANSFORMER MOUNTING BRACKET	1	RABING AS SPECIFIED
10	TRANSFORMER MOUNTING BRACKET	1	SEE DRAWING SHEET-11
11	W/ EARTH CONDUCTOR	15m	BARE COPPER CONDUCTOR 70mm ²
12	W/ EARTH CONDUCTOR	20m	Ø74.00mm STAY WIRE
13	SHOULDS	10	
14	ROCK PIPE	3m	H0PE 50mmø
15	SPARKS	4	3x32mm HOT DIP GALVANISED
16	EARTH SPRING	4	12m LONG - 10mmø
17	STAY INSULATOR	2	CULLINAN, Z1-0922
18	POLE TOP MAKE OFF	2	PIP- P14 Z
19	GUT GRP	6	PIP- GSIE-472
20	STAY WIRE GALVANISED	2	CULLINAN BS20 C/W THIMBLE
21	STAY ROD	30m	Ø74.00 STAY WIRE GALVANISED
22	BASE PLATE	2	CULLINAN 450x450x8mm GALV
23	GOPIHER JUMPERS	8x3m	GOPIHER ALUMINIUM CONDUCTOR
24	TRANSFORMER BUSHINGS	3	SUPPLIED WITH TRIS
25	TERMINATION LUGS	3	ALUMINIUM TO BRASS 70x16
26	WOODEN POLE	1	11m LONG WITH TOP 160mmø
27	POLE CAP	1	
28	DANGER PLATE	1	

NOTES:

ELECTRICITY CONTROL BOARD



Box: 29223
 Windhoek
 NAMIBIA
 Tel: (061) 374300
 Fax: (061) 374305

MEDIUM VOLTAGE BARE OVERHEAD DISTRIBUTION
 DISTRIBUTION TRANSFORMER STRUCTURE
 SINGLE POLE MOUNTING

DESIGNED: A.K
 DRAWN: J.W.S
 REV: 01-2001
 DRAWING No: STD-MVAE-11KV-02
 SCALE: N.T.S

ERROR: syntaxerror
OFFENDING COMMAND: --nostringval--

STACK:

/Title
()
/Subject
(D:20100127124342+02'00')
/ModDate
()
/Keywords
(PDFCreator Version 0.9.5)
/Creator
(D:20100127124342+02'00')
/CreationDate
(johnny)
/Author
-mark-