



COPYRIGHT © 2009 EMCON
 ALL RIGHTS RESERVED. NO PART OF THIS PUBLICATION MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC, MECHANICAL, PHOTOCOPYING, RECORDING, MAGNETIC TAPE, MECHANICAL, PHOTOCOPYING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE PERMISSION IN WRITING FROM EMCON.



ITEM	DESCRIPTION	QTY	REMARKS
1	WOODEN POLE	1	11m LONG TOP 180mm ϕ
2	STRAIN A-FRAME	1	SEE DWG NO. STD-MVAF-11
3	BOLTS & NUTS FOR WASHERS	3	M16X200mm COMPLETE
4	LONGER INSULATOR	3	COLLINK, EP-342, S85 GREYPAGE
5	SHORT INSULATOR	3	COLLINK, Z1-0322
6	THIMBLE GLENS	3	EP-MIG 250
7	DEAD END	3	EP-MIG 250
8	5/8" ROD	3	B320 C/W THIMBLE M20X2000
9	POLE EARTH CONDUCTOR	11	3/4"X4000mm HOT DIP GALVANISED
10	STAPLES	30	3X2527mm HOT DIP GALVANISED
11	BAND-HI STRAPPING	1	250X77mm STAINLESS STEEL
12	BAND-FLATE	1	450X450x6mm GALVANISED
13	SOFT GRIP	3	FLP-G3DE 41/2
14	POLE TOP MAKE OFF	3	FLP-F1 41/2
15	5/8" WIRE GALVANISED	15	17/4,500 STAYWIRE GALVANISED
16	POLE CAP		
17	DANGER PLATE		

NOTES:
 1. STRAIN A-FRAME AND POLE TOP MAKE OFF MUST BE PROPERLY CONNECTED TO EARTH.

ELECTRICITY CONTROL BOARD



Box 2923
 Windhoek
 NAMIBIA
 Tel: (061) 224725
 Fax: (061) 233207

**MEDIUM VOLTAGE BARE OVERHEAD DISTRIBUTION
 END POLE STRUCTURE**

DESIGNED: A.K	DRAWN: J.W.S	REV: 01-2001
DRAWING No: STD-MVAF-11K-V-04	SCALE: N.T.S	

ERROR: syntaxerror
OFFENDING COMMAND: --nostringval--

STACK:

/Title
()
/Subject
(D:20100127124207+02'00')
/ModDate
()
/Keywords
(PDFCreator Version 0.9.5)
/Creator
(D:20100127124207+02'00')
/CreationDate
(johnny)
/Author
-mark-