


COPYRIGHT © 2009 EMCOR
 ALL RIGHTS RESERVED. NO PART OF THIS PUBLICATION MAY BE REPRODUCED STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC, MECHANICAL, PHOTOCOPYING, RECORDING OR OTHERWISE, WITHOUT THE PERMISSION IN WRITING FROM EMCOR.

ITEM	DESCRIPTION	QTY	REMARKS
------	-------------	-----	---------

1	CURVED "C" WASHER & DOUBLE NUTS	2	VC37
2	254mm x 20mm EYE-BOLT COMPLETE	1	VC34
3	D-SCHWACKLE	1	VC12
4	LONGROD 33kV STRAIN INSULATOR	2	33kV ELBROC CAT NO. 810902
5	CLEVIS THIMBLE	2	PUP MCT0
6	DEAD END FOR MAGPIE	2	PUP D020 250
7	3 BOLT PG CLAMPS (GOLD)	4	PUP 1046-3G
8	SPIRAL VIBRATION DAMPERS	2	PUP S034
9	D.O.F ASSEMBLY FOR 33kV LINE	2	NOX 33kV
10	ELECTRONIC SINGLE PHASE SECTIONALISER	2	ISOTECH ES/12/24-01
11	CROSS-ARM	1	
12	BOLT 20x200mm	1	552 x 50 x 6mm "EBW"
13	BRACKING STRAP	1	12m
14	3x4 DIAMETER STAY WIRE	1	POLE EARTH
15	EARTH SPIKE	4	1.2m LONG, 16mmø

NOTES:

ELECTRICITY CONTROL BOARD



Box 2923
 Windhoek
 NAMIBIA
 Tel: (061) 374300
 Fax: (061) 374305

DRAWING TITLE
 LOW VOLTAGE AERIAL BUNDLE
 CONDUCTOR DISTRIBUTION SYSTEM
 DISTRIBUTION TRANSFORMER CONNECTION
 LOCAL AUTHORITY

DESIGNED: AAK	DRAWN: J.W.S	REV: 01-2001
DRAWING No: STD-SWER-14	SCALE: N.T.S	

ERROR: syntaxerror
OFFENDING COMMAND: --nostringval--

STACK:

/Title
()
/Subject
(D:20100127143228+02'00')
/ModDate
()
/Keywords
(PDFCreator Version 0.9.5)
/Creator
(D:20100127143228+02'00')
/CreationDate
(johnny)
/Author
-mark-